

WELL OR BORING LOCATION

County Name

Hennepin

Township Name

Orono

Township No.

117

Range No.

23

Section No.

07

Fraction (sm. → lg.)

SW SE NE

GPS LOCATION – decimal degrees (to four decimal places)

Latitude

Longitude

Numerical Street Address or Fire Number and City of Well or Boring Location

1045 North Arm Dr, Orono

Show exact location of well or boring in section grid with "X."

N

W

E

S

1 Mile

1/2 Mile

Sketch map of well or boring location, showing property lines, roads, and buildings.

North arrow

Well location

MINNESOTA Well and Boring Sealing No.

Minnesota Unique Well No. or W-series No.

(Leave blank if not known)

MINNESOTA Well and Boring Sealing No.

Minnesota Unique Well No. or W-series No.

(Leave blank if not known)

WELL AND BORING SEALING RECORD

Minnesota Statutes, Chapter 103I

DATE Sealed

7/02/19

DATE Well or Boring Constructed

DEPTH at Time of Sealing

109'

ft.

ORIGINAL Depth

ft.

AQUIFER(S)

☒ Single Aquifer ☐ Multiaquifer

WELL/BORING

☒ Water-Supply Well ☐ Env. Well ☐ Temp. Env. Well ☐ Other

STATIC WATER LEVEL

☒ Measured ☐ Estimated

Date Measured

SAME DAY

92'

ft.

☒ below ☐ above land surface

CASING TYPE(S)

☒ Steel ☐ Plastic ☐ Tile ☐ Other

WELLHEAD COMPLETION

Outside: ☒ Pitless Adapter/Unit ☐ At Grade ☐ Well Pit ☐ Other

Inside: ☐ Basement Offset ☐ Well House ☐ Well Pit ☐ Buried ☐ Other

CASING(S)

Diameter

4" in. from 0' to 105' ft.

Depth

105'

Set in oversized hole?

☐ Yes ☒ No

Annular space initially grouted?

☐ Yes ☐ No ☐ Unknown

SCREEN/OPEN HOLE

Screen from 105' to 109' ft.

Open Hole from

to

ft.

OBSTRUCTIONS

☒ Rods/Drop Pipe ☐ Check Valve(s) ☐ Debris ☐ Fill ☐ No Obstruction

Type of Obstructions (Describe)

INNER PIPE & PUMP

Obstructions removed?

☒ Yes ☐ No

Describe

PUMP

☐ Not Present ☒ Present, Removed Prior to Sealing ☐ Other

Type

SUB Pump

METHOD USED TO SEAL ANNULAR SPACE BETWEEN 2 CASINGS, OR CASING AND BORE HOLE

☒ No Annular Space Exists ☐ Annular Space Grouted with Tremie Pipe ☐ Casing Perforation/Removal

Casing Diameter

in. from

to

ft.

☐ Perforated ☐ Removed

VARIANCE

Was a variance granted for the MDH for this well?

☐ Yes ☒ No

TN#

GROUTING MATERIAL(S)

(One bag of cement = 94 lbs., one bag of bentonite = 50 lbs.)

Grouting Material

NEAT CEMENT

from 0' to 109' ft.

yards

9

bags

OTHER WELLS AND BORINGS

Other unsealed and unused well or boring on property?

☐ Yes ☒ No

How many?

LICENSED OR REGISTERED CONTRACTOR CERTIFICATION

This well or boring was sealed in accordance with Minnesota Rules, Chapter 4725. The information contained in this report is true to the best of my knowledge.

Don Stodola Well Drilling Co, Inc.

1691

Licensee Business Name

License or Registration No.

7-9-19

Certified Representative Signature

Certified Rep. No.

Date

Jim Antonson

Name of Person Sealing Well or Boring

REMARKS, SOURCE OF DATA, DIFFICULTIES IN SEALING

LOCAL COPY

H 365918