

**CITY OF ORONO
INSPECTION NOTICE**

PERMIT NO. SNP22-000047

CALLLED IN
SCHEDULED
COMPLETED

DATE

TIME

9/19/22

9/20/22

9/27/22

1:30 PM

1:30 PM

ADDRESS 1856 Shadywood Rd

OWNER _____ **TELEPHONE NO.** 602 919 4340

CONTRACTOR MIKE Arnt - DSM Excavating

DESCRIPTION Sewer & Water Connection

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 4" Sch 40 pvc sewer service with tracer
wire & Anode, 90' to clean out + Total pipe 190'
from 6" to main was lined (overseer)
5lb air test for 15 minutes All ok

1" Endopure IPS water service with Tracer
wire.

☒ **WORK SATISFACTORY: PROCEED**

- ☐ CORRECT WORK & PROCEED
- ☐ CORRECT WORK, CALL FOR REINSPECTION
BEFORE COVERING

☐ CORRECT UNSAFE CONDITION WITHIN _____ HOURS.
INSPECTOR WILL RETURN

☐ STOP ORDER POSTED. CALL INSPECTOR

☐ INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.

☒ **PROJECT COMPLETE**

☐ **ISSUE CERTIFICATE OF OCCUPANCY**

_____ **TEMPORARY**

_____ **PERMANENT**

☒ **PHOTO TAKEN**

☐ **CITATION ISSUED**

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: DSM

Inspector: Scott