

**CITY OF ORONO  
INSPECTION NOTICE  
PERMIT NO. SWP22-000066**

CALLED IN  
SCHEDULED  
COMPLETED

DATE

TIME

9/22

1100 AM

ADDRESS 1000 Tonkawa

OWNER \_\_\_\_\_ TELEPHONE NO. \_\_\_\_\_

CONTRACTOR Tom 612-868 8072

DESCRIPTION Sewer Connect

- |  |  |  |
|--|--|--|
| <input type="checkbox"/> FOOTING               | <input type="checkbox"/> DEMO - FINAL          | <input type="checkbox"/> SEPTIC FINAL          |
| <input type="checkbox"/> POURED WALL           | <input type="checkbox"/> PLUMBING RI           | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL        | <input type="checkbox"/> TREE REMOVAL          |
| <input type="checkbox"/> LATHE                 | <input type="checkbox"/> MECHANICAL RI         | <input type="checkbox"/> SITE INSPECTION       |
| <input type="checkbox"/> FRAMING               | <input type="checkbox"/> MECHANICAL FINAL      | <input type="checkbox"/> RATED WALLS           |
| <input type="checkbox"/> INSULATION            | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT             |
| <input type="checkbox"/> FINAL                 | <input type="checkbox"/> WATER HOOK-UP         | <input type="checkbox"/> FOLLOW-UP             |
| <input type="checkbox"/> AS BUILT - SURVEY     | <input type="checkbox"/> SEWER HOOK-UP         | <input type="checkbox"/> FOUNDATION/REMOVAL    |
| <input type="checkbox"/> DEMO - SITE           | <input type="checkbox"/> SEPTIC INSTALL        |  |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 4" sch 40 pvc out 25' with tracer  
wire hooked to cast iron pipe. Contractor  
was told to either line cast iron or  
install new sch 40 pvc with Anode +  
Tracer wire.  
5lb test on 25' was all ok

- |  |   |
|--|---|
| <input type="checkbox"/> WORK SATISFACTORY: PROCEED  | <input type="checkbox"/> PROJECT COMPLETE               |
| <input type="checkbox"/> CORRECT WORK & PROCEED  | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input checked="" type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION<br>BEFORE COVERING             | <u>      </u> TEMPORARY                                 |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN <u>      </u> HOURS.<br>INSPECTOR WILL RETURN | <u>      </u> PERMANENT                                 |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR   | <input type="checkbox"/> PHOTO TAKEN                    |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.                                  | <input type="checkbox"/> CITATION ISSUED                |

**Call for the next inspection 24 hours in advance. (952) 249-4600**

Owner/Contractor on site: \_\_\_\_\_

Inspector: Scott