

From: gnelson@oronomn.gov
Sent: 10/31/2023 - 01:15 PM
To: nate@customonehomesmn.com
CC: gnelson@oronomn.gov
Subject: Inspection Report Individual



CITY OF ORONO
2750 KELLEY PARKWAY
ORONO, MN 55356
PH: (952) 249-4600
FAX: (952) 249-4616

Inspection Report

1025 Wildhurst TRL

Permit Number: RAS23-000004
Site Address: 1025 Wildhurst TRL, Orono, MN 55364
Property Owner: Jacob Goergen & April Will
Description: Boulder Walls

Inspection Date: 10/31/2023
Inspection Type: Building Final
Inspection Results: **Permit Finaled**

Inspection Status: Review Comment

1. Drainage pipe is visible. Geo fabric is visible. Wall is 7 ft. At max height. Base stones are large enough. Walls were engineered to 10 ft.

Sincerely,

Gary Nelson
952-242-4442

To schedule your inspections please call: (952) 249-4600

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!