



617 13th Ave S.,  
Hopkins, MN 55343  
(952) 935-3556  
tcwaterclinic@gmail.com

## Drinking Water Laboratory Test Report

Report #:  
23-11122

Report Issue Date:  
10/17/2023

### CLIENT INFORMATION

CLIENT/CLIENT ADDRESS:  
Don Stodola Well Drilling  
3841 North Main Street St. Bonifacius, MN 55375  
WELL #:  
869418

OWNER/OWNER ADDRESS:  
Brian & Tressa Dahl  
WELL ADDRESS:  
941 North Arm Drive Orono, MN

### SAMPLE RESULTS

DATE/TIME COLLECTION OF SAMPLE:  
10/16/2023 - 10:40

DATE/TIME OF SAMPLE RECEIPT:  
10/16/2023 - 11:09

SAMPLE RECEIVED ON ICE:

☒ YES

☐ NO

TEMP. OF SAMPLE UPON RECEIPT:  
17° C

SAMPLE COLLECTION POINT:  
Well

COLLECTED BY:  
☐ TCWC ☒ CLIENT ☐ OTHER

### SAMPLE RESULTS

LABORATORY SAMPLE ID:  
23-11122

CLIENT ID:

ANALYTE	PASS/FAIL*	Result	MCL	ANALYSIS DATE	ANALYSIS TIME	METHOD
Total Coliform	PASS ✓	ABSENT	<1 cfu/100mL	10/16/2023	13:53	SM9222B (M-Endo) + G (EC MUG) -97
Nitrate as N	PASS ✓	<1.0 mg/L	10 mg/L	10/17/2023	15:53	EPA 353.2 Rev 2.0
Arsenic	PASS ✓	5.94 µg/L	10 µg/L	10/17/2023	13:43	SM3113B-93

\* The analyte(s) reported, for the above listed sample(s) pass if the result is below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

### NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

### Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health unless otherwise noted.