



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

Report #: 23-11594 Report Issue Date: 10/27/2023

CLIENT INFORMATION

CLIENT/CLIENT ADDRESS: Don Stodola Well Drilling
3841 North Main Street St. Bonifacius, MN 55375
WELL #: 869421
OWNER/OWNER ADDRESS: Hendel Homes
WELL ADDRESS: 3345 Fox St Orono, MN

SAMPLE RESULTS

DATE/TIME COLLECTION OF SAMPLE: 10/25/2023 - 12:36 DATE/TIME OF SAMPLE RECEIPT: 10/25/2023 - 13:56
SAMPLE RECEIVED ON ICE: YES NO TEMP. OF SAMPLE UPON RECEIPT: 15° C
SAMPLE COLLECTION POINT: Well COLLECTED BY: TCWC CLIENT OTHER

SAMPLE RESULTS

LABORATORY SAMPLE ID: 23-11594 CLIENT ID:

ANALYTE	PASS/FAIL*	Result	MCL	ANALYSIS DATE	ANALYSIS TIME	METHOD
Total Coliform	FAIL X	PRESENT	<1 cfu/100mL	10/25/2023	16:13	SM9222B (M-Endo) + G (EC MUG) -97
Nitrate as N	PASS ✓	<1.0 mg/L	10 mg/L	10/26/2023	13:14	EPA 353.2 Rev 2.0
Arsenic	PASS ✓	4.43 µg/L	10 µg/L	10/27/2023	12:12	SM3113B-93

* The analyte(s) reported, for the above listed sample(s) pass if the result is below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health unless otherwise noted.