

From: gnelson@oronomn.gov
Sent: 12/12/2023 - 08:08 AM
To: dan@covebuilders.com
CC: gnelson@oronomn.gov,jruthenberg@oronomn.gov
Subject: Inspection Report Individual



CITY OF ORONO
2750 KELLEY PARKWAY
ORONO, MN 55356
PH: (952) 249-4600
FAX: (952) 249-4616

Inspection Report

2720 Fox ST

Permit Number: RPS23-000128
Site Address: 2720 Fox ST, Orono, MN 55391
Property Owner: L M STUBBS & D E STUBBS
Description: Updating of Kitchen, bathrooms and finish basement

Inspection Date: 12/08/2023
Inspection Type: Building Final
Inspection Results: **Permit Finaled**

Inspection Status: Complete

1. safety Glazing required in master bath , main level Photos received on 12/11/2023.

Sincerely,

A handwritten signature in black ink, appearing to read "Gary Nelson", with a long horizontal flourish extending to the right.

Gary Nelson
952-242-4442

To schedule your inspections please call: (952) 249-4600

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!