

Jim Eicher



Septic Service, LLC
1205 LaBeaux Ave NE
St. Michael, MN 55376

Maintenance Inspection Form

MPCA Lic. #L4286

Maintainer

☐ Jim
☒ Nick

• Phone: 763-497-2764

• Email: duaneseptic@centurylink.net

DATE 11-22-23

INVOICE

Pumping Fee: <u>\$437.50</u>	Name: <u>Thoresen, Cassie</u>
Long Pull Fee: <u>\$125.00</u>	Address: <u>3300 Graham Hill Rd</u>
Other Repairs:	City/State/Zip: <u>Orono</u>
Total Cost of Service: <u>\$562.50</u>	Payment Method: ☐ Check ☐ Cash ☐ Credit

Tank (check if present)	Tank leaks below the designed operating depth	Tank leaks above the designed operating depth	Maintenance hole cover is damaged, cracked, unsecured, or appears to be structurally unsound
☒ Septic/holding Tank #1 Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No
☒ Septic/holding Tank #2 Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No
☐ Pretreatment Tank Gallons:	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
☒ Pump Tank Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No

How Accessed: ☒ Maintenance Hole ☐ Other (see attached)	Scum/Sludge Measured ☒ Yes ☐ No	Maintenance Holes Securely Replaced: ☒ Yes ☐ No	Reason For Pumping: <u>maint</u>
---	---	---	-------------------------------------

Did you identify any operational issues or unsafe conditions while assessing the sewage tanks in this system, i.e., cracked tanks, missing baffles, broken covers, etc.? If so, explain in comments below.

Tank #1	Tank #2	Pump Tank	System
☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☒ Mound
☐ Structural integrity	☐ Structural integrity	☐ Structural integrity	☐ Elevated drainfield
☐ Risers leaking	☐ Risers leaking	☐ Risers leaking	☐ Pressure bed
☐ Baffles	☐ Baffles	☐ Baffles	☐ Trenches
☐ Non-domestic waste	☐ Non-domestic waste	☐ Electrical issues	☐ Ponding/Surfacing
		☐ Non-domestic waste	☐ Other:
		☐ Effluent Filter/screen	
		Cleaned? ☐ Yes ☐ No	

Comments:

Disposal: ☐ Land Application: ☒ Wastewater Treatment Plant Watertown

Disposal Site:	Lime:	Gallons <u>2200</u>	Plowed: ☐ Yes ☐ No
Time:		Temperature:	pH: <u>> 12</u> ☐
Time:		Temperature:	pH: <u>> 12</u> ☐

