

Jim Eicher



Septic Service, LLC
1205 LaBeaux Ave NE
St. Michael, MN 55376

Maintenance Inspection Form

MPCA Lic. #L4286

Maintainer

☒ Jim

☐ Nick

• Phone: 763-497-2764

• Email: duaneseptic@centurylink.net

DATE 9-19-23

INVOICE

Pumping Fee:	Name: <u>Eckertine, Peter</u>
Long Pull Fee:	Address: <u>1070 Hunter Dr.</u>
Other Repairs:	City/State/Zip: <u>Orono</u>
Total Cost of Service: <u>\$462.50</u>	Payment Method: ☐ Check ☐ Cash ☐ Credit

Tank (check if present)	Tank leaks below the designed operating depth	Tank leaks above the designed operating depth	Maintenance hole cover is damaged, cracked, unsecured, or appears to be structurally unsound
☒ Septic/holding Tank #1 Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No
☒ Septic/holding Tank #2 Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No
☐ Pretreatment Tank Gallons:	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
☒ Pump Tank Gallons: <u>1250</u>	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No

How Accessed: ☒ Maintenance Hole ☐ Other (see attached)	Scum/Sludge Measured ☐ Yes ☒ No	Maintenance Holes Securely Replaced: ☒ Yes ☐ No	Reason For Pumping: <u>good</u>
---	---	---	------------------------------------

Did you identify any operational issues or unsafe conditions while assessing the sewage tanks in this system, i.e., cracked tanks, missing baffles, broken covers, etc.? If so, explain in comments below.

Tank #1	Tank #2	Pump Tank	System
☐ Structural integrity ☐ Risers leaking ☐ Baffles ☐ Non-domestic waste	☐ Structural integrity ☐ Risers leaking ☐ Baffles ☐ Non-domestic waste	☐ Structural integrity ☐ Risers leaking ☐ Baffles ☐ Electrical issues ☐ Non-domestic waste ☐ Effluent Filter/screen Cleaned? ☐ Yes ☐ No	☒ Mound ☐ Elevated drainfield ☐ Pressure bed ☐ Trenches ☐ Ponding/Surfacing ☐ Other:

Comments:

Disposal: ☒ Land Application: ☐ Wastewater Treatment Plant

Disposal Site: <u>9</u>	Lime: <u>✓</u>	Gallons: <u>2500</u>	Plowed: ☐ Yes ☒ No
Time: <u>10:40</u>		Temperature: <u>71</u>	pH: <u>12.3</u> > 12 ☐
Time: <u>11:20</u>		Temperature: <u>70</u>	pH: <u>12.3</u> > 12 ☐

