

**From:** gnelson@oronomn.gov  
**Sent:** 11/30/2023 - 10:26 AM  
**To:** kari.s@highmarkcos.com  
**CC:** gnelson@oronomn.gov  
**Subject:** Inspection Report Individual

---



**CITY OF ORONO**  
**2750 KELLEY PARKWAY**  
**ORONO, MN 55356**  
**PH: (952) 249-4600**  
**FAX: (952) 249-4616**

---

## **Inspection Report**

### **2871 Casco Point Road**

---

Permit Number: RBG23-000037  
Site Address: 2871 Casco Point Road, Orono, MN 55391  
Property Owner: R E WOLFE  
Description: Re Sid

---

Inspection Date: 11/30/2023  
Inspection Type: Building Final  
Inspection Results: **Permit Finaled**

#### **Inspection Status:** Review Comment

1. Added required hand and guard rail per code. Added required deck flashing at hose connection. Mechanical connectors as required and added framing connections/additions as necessary for required bearing At existing point loads.

Sincerely,

Gary Nelson  
952-242-4442

***To schedule your inspections please call: (952) 249-4600***

**CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!**