

CITY OF ORONO  
INSPECTION NOTICEPERMIT NO. SWP23-000022CALLED IN  
SCHEDULED  
COMPLETED

DATE

4/7/23

TIME

2:00 PMADDRESS 725 6<sup>m</sup> Ave North (Spring Hill Golf Club)

OWNER

TELEPHONE NO.

763-286-8291

CONTRACTOR

Roto RooterBlaine →

## DESCRIPTION

Sewer Permit Inspection

- |  |  |  |
|--|--|--|
| <input type="checkbox"/> FOOTING               | <input type="checkbox"/> DEMO - FINAL          | <input type="checkbox"/> SEPTIC FINAL          |
| <input type="checkbox"/> POURED WALL           | <input type="checkbox"/> PLUMBING RI           | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL        | <input type="checkbox"/> TREE REMOVAL          |
| <input type="checkbox"/> LATHE                 | <input type="checkbox"/> MECHANICAL RI         | <input type="checkbox"/> SITE INSPECTION       |
| <input type="checkbox"/> FRAMING               | <input type="checkbox"/> MECHANICAL FINAL      | <input type="checkbox"/> RATED WALLS           |
| <input type="checkbox"/> INSULATION            | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT             |
| <input type="checkbox"/> FINAL                 | <input type="checkbox"/> WATER HOOK-UP         | <input type="checkbox"/> FOLLOW-UP             |
| <input type="checkbox"/> AS BUILT - SURVEY     | <input type="checkbox"/> SEWER HOOK-UP         | <input type="checkbox"/> FOUNDATION/REMOVAL    |
| <input type="checkbox"/> DEMO - SITE           | <input type="checkbox"/> SEPTIC INSTALL        |  |

OWNER/CONTRACTOR TO MEET YOU: YES NO

## COMMENTS:

Roto Rooter found buried manhole  
exposed it + removed Grease ball, a  
plastic bag + under wear + clog with  
power. Clean out 10' East of manhole  
is cracked + needs to be fixed.

- |   |   |
|---|---|
| <input type="checkbox"/> WORK SATISFACTORY: PROCEED   | <input type="checkbox"/> PROJECT COMPLETE               |
| <input type="checkbox"/> CORRECT WORK & PROCEED   | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING                            | <u>          </u> TEMPORARY                             |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN <u>          </u> HOURS. INSPECTOR WILL RETURN | <u>          </u> PERMANENT                             |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR  | <input type="checkbox"/> PHOTO TAKEN                    |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.                                   | <input type="checkbox"/> CITATION ISSUED                |

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site:

Blaine

Inspector:

Scott