

CITY OF ORONO  
INSPECTION NOTICE  
PERMIT NO. SNP23-000039

DATE 8/9/23 TIME 8:30 AM  
CALLED IN 8/10/23  
SCHEDULED  
COMPLETED

ADDRESS 3345 FOX ST.

OWNER \_\_\_\_\_ TELEPHONE NO. \_\_\_\_\_

CONTRACTOR \_\_\_\_\_

DESCRIPTION Sewer Connect

- FOOTING
- POURED WALL
- FOUNDATION DRAIN TILE
- LATHE
- FRAMING
- INSULATION
- FINAL
- AS BUILT - SURVEY
- DEMO - SITE
- DEMO - FINAL
- PLUMBING RI
- PLUMBING FINAL
- MECHANICAL RI
- MECHANICAL FINAL
- WOOD BURNER/FIREPLACE
- WATER HOOK-UP
- SEWER HOOK-UP
- SEPTIC INSTALL
- SEPTIC FINAL
- EXCAV/GRADING/FILLING
- TREE REMOVAL
- SITE INSPECTION
- RATED WALLS
- COMPLAINT
- FOLLOW-UP
- FOUNDATION/REMOVAL

OWNER/CONTRACTOR TO MEET YOU: NO YES NO

COMMENTS: 30' x 4" sch 40 pipe from home to E-1 station.  
E-1 has pool, detached building + home going to it.

5 lb air test for 15 minutes on 4" +  
10 lb test on 1.05"

All ok

- WORK SATISFACTORY: PROCEED
- CORRECT WORK & PROCEED
- CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING
- CORRECT UNSAFE CONDITION WITHIN \_\_\_\_\_ HOURS. INSPECTOR WILL RETURN
- STOP ORDER POSTED. CALL INSPECTOR
- INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.
- PROJECT COMPLETE
- ISSUE CERTIFICATE OF OCCUPANCY \_\_\_\_\_ TEMPORARY \_\_\_\_\_ PERMANENT
- PHOTO TAKEN
- CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: Eric

Inspector: Scott

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!