

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

CITY OF ORONO
INSPECTION NOTICE

PERMIT NO. SWP21000076

12-20
DATE
12/16/21
9:30
TIME
11:00
CALLED IN
SCHEDULED
COMPLETED

ADDRESS 2420 S. Blossum Cir

OWNER _____ TELEPHONE NO. 651-442-1257

CONTRACTOR Pete

DESCRIPTION

- | | | |
|--|---|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input checked="" type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input checked="" type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 41 Sch 40 Sewer Service with tracer wire
4" and 6"

5/6 test for 15 min - All ok

1.5" Endopore Water Service with tracer
wire and 6"

☒ WORK SATISFACTORY: PROCEED

☐ CORRECT WORK & PROCEED

☐ CORRECT WORK, CALL FOR REINSPECTION
BEFORE COVERING

☐ CORRECT UNSAFE CONDITION WITHIN _____ HOURS.
INSPECTOR WILL RETURN

☐ STOP ORDER POSTED. CALL INSPECTOR

☐ INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.

☐ PROJECT COMPLETE

☐ ISSUE CERTIFICATE OF OCCUPANCY

_____ TEMPORARY

_____ PERMANENT

☐ PHOTO TAKEN

☐ CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: Ground Tech

Inspector: Scott

White Copy/Inspector's File

Canary Copy/Site Notice