

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

CITY OF ORONO

INSPECTION NOTICE

PERMIT NO. SWP25-000050

CALLED IN

SCHEDULED

COMPLETED

DATE

TIME

7/29/25

8 am

ADDRESS 1105 Brown Road South

OWNER _____ TELEPHONE NO. _____

CONTRACTOR Marvel Sewer + Drain - Ben Smith

DESCRIPTION Sewer Repair

- FOOTING
- POURED WALL
- FOUNDATION DRAIN TILE
- LATHE
- FRAMING
- INSULATION
- FINAL
- AS BUILT - SURVEY
- DEMO - SITE
- DEMO - FINAL
- PLUMBING RI
- PLUMBING FINAL
- MECHANICAL RI
- MECHANICAL FINAL
- WOOD BURNER/FIREPLACE
- WATER HOOK-UP
- SEWER HOOK-UP
- SEPTIC INSTALL
- SEPTIC FINAL
- EXCAV/GRADING/FILLING
- TREE REMOVAL
- SITE INSPECTION
- RATED WALLS
- COMPLAINT
- FOLLOW-UP
- FOUNDATION/REMOVAL

OWNER/CONTRACTOR TO MEET YOU: ___ YES ___ NO

COMMENTS:

Missed Inspection. Hunter Reviewed Video of Repair.

Repaired Mineral Deposits @ 113' & 125' With two 2' patches Installed through The Clean out.

Task # 96880

- WORK SATISFACTORY: PROCEED
- CORRECT WORK & PROCEED
- CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING
- CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN
- STOP ORDER POSTED. CALL INSPECTOR
- INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.
- PROJECT COMPLETE
- ISSUE CERTIFICATE OF OCCUPANCY _____ TEMPORARY _____ PERMANENT
- PHOTO TAKEN
- CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: _____

Inspector: Hunter Gille