

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

CITY OF ORONO
INSPECTION NOTICE

PERMIT NO. SWP23-000023

CALLED IN
SCHEDULED
COMPLETED

DATE
4/11/23
4/17/23
4/17/23

TIME

7:30 PM
5:00

ADDRESS 1520 Green Trees Rd

OWNER

TELEPHONE NO

Joel 763-286-2978

CONTRACTOR

Kohrman Sewer, Water & Excavating

DESCRIPTION

Sewer Connect

- | | | |
|--|---|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input checked="" type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 4" from garage 29' to E1 pump station then 1/4" to 2" curb stop

Air test 4" with tracer wire - 5 lb air test for 15 minutes All good

100 PSI for 1/4"

All good

☒ WORK SATISFACTORY: PROCEED

☐ CORRECT WORK & PROCEED

☐ CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING

☐ CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN

☐ STOP ORDER POSTED. CALL INSPECTOR

☐ INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.

☒ PROJECT COMPLETE

☐ ISSUE CERTIFICATE OF OCCUPANCY

_____ TEMPORARY

_____ PERMANENT

☒ PHOTO TAKEN

☐ CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site:

Gleny

Inspector:

JOHN