

12/4/2023

Name: Kellie Hoen

Date Called in	
Date Scheduled	11/30/2023

## City Of Orono Point of Sale Sanitary Sewer Service I&I Compliance Inspection Form

TESHOR!	int of S.	are summerly server service	e icai compilance inspec	tion I of				
Property Address: 2726 Caroline Avenue								
PID:								
		Owner In	formation		1			
Name:								
Mailing Address: (if different from Property)								
Phone:	Email:							
		Inspector In	nformation					
Name:								
Company/ Organizati			License number:					
Phone:			Email:					
· ·								
		Inspe	ction					
System	Stand		11 11 11	.,	Pass	Fail		
Roof Drains	Roof drains and leaders Roof drains should not be connected to the sanitary sewer but should discharge to the ground outside of a building. If the roof drains are connected to the sanitary sewer, disconnect them, plug any open connections to the sanitary sewer using a non-shrink permanent material, and redirect the roof drains onto the ground outside the building.				X			
Foundation	Foundation drains are underground pipes that collect storm water from				x			
Drains	around the base of a building and into a sump basket, where it is then pumped outside of the building. Foundation drains should not be connected to the sanitary sewer.							
Sump Pumps	Sump pumps are designed to capture surface or ground water that enters basements or crawl spaces and pump it away from the house. The basic sump system includes drain tile, a sump pit, a sump pump, a float or switch, and a drain line. Sump pumps should not be connected to the sanitary sewer.				Х			
Sewer Service Line	Sanitary Sewer Inflow & Infiltration (I/I) Compliance Inspection Sanitary Sewer Lines. All sanitary sewer lines serving Property, from the house to the main line, shall be in a safe and functional condition and shall be free from all leaks, failures including but not limited to partially collapsed sections or tree root intrusion. The sanitary sewer lines shall meet the City Code standards and specifications. (Details on back of this sheet)							
Notes:	New service connected to new home 11/30/2023. 4" Sch40 PVC with tracer wire and anode 100 feet from house to cleanout by the lake							
Toilet Removed For Inspection:	l ∘ Yes ∘ No							
1 0			Date:					
Owners Signature: Date:								
City Review								
Corrective Action Required								
Certificate of Compliance Expires: 11/30/2033 Corrective Action Due by:								
Date: Signature: Kellenberg								