

**CITY OF ORONO
INSPECTION NOTICE
PERMIT NO.**

**CALL IN
SCHEDULED
COMPLETED**

DATE
6/28/22
6/30/22

TIME
10:30 AM

ADDRESS 15 Myrtlewood Road

OWNER _____ **TELEPHONE NO.** 612 644 3153

CONTRACTOR Hentges Land Corp

DESCRIPTION Disconnect (Sewer & Water) Inspection

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 4" Sch 40 pipe disconnected

Water disconnected

Curbside (sewer) turned off

- | | |
|---|---|
| <input checked="" type="checkbox"/> WORK SATISFACTORY: PROCEED | <input type="checkbox"/> PROJECT COMPLETE |
| <input type="checkbox"/> CORRECT WORK & PROCEED | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING | <u> </u> TEMPORARY |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN <u> </u> HOURS. INSPECTOR WILL RETURN | <u> </u> PERMANENT |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR | <input type="checkbox"/> PHOTO TAKEN |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS. | <input type="checkbox"/> CITATION ISSUED |

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: _____

Inspector: SCOTT

