

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

**CITY OF ORONO
INSPECTION NOTICE**

PERMIT NO. SNP22-000063

CALLER IN
SCHEDULED
COMPLETED

DATE

9/9/20
9/12/22

TIME

10:30 AM

ADDRESS 90 Creek Ridge Pass

OWNER

TELEPHONE NO.

CONTRACTOR Poppitz

Troy 612-369-1110

DESCRIPTION

Sewer Connection (to water?)

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS:

1" Sch 40 pipe Sewer Service

with tracer wire

5 lb air test - All OK

1" IPS - water service with tracer wire

- | | |
|---|---|
| <input type="checkbox"/> WORK SATISFACTORY: PROCEED | <input checked="" type="checkbox"/> PROJECT COMPLETE |
| <input type="checkbox"/> CORRECT WORK & PROCEED | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING | <u> </u> TEMPORARY |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN <u> </u> HOURS. INSPECTOR WILL RETURN | <u> </u> PERMANENT |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR | <input checked="" type="checkbox"/> PHOTO TAKEN |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS. | <input type="checkbox"/> CITATION ISSUED |

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site:

Inspector:

White Copy/Inspector's File

Canary Copy/Site Notice