

DATE

TIME

CALLED IN
SCHEDULED
COMPLETED

10/19

2:00 PM

CITY OF ORONO
INSPECTION NOTICE
PERMIT NO. WP22-000085

ADDRESS 2200 Bayview Place

OWNER

TELEPHONE NO. 612 508 9974

CONTRACTOR Bill Coppin

DESCRIPTION

Sewer Repair (Failed 1/1 on 8/24/22)

- ☐ FOOTING
☐ POURED WALL
☐ FOUNDATION DRAIN TILE
☐ LATHE
☐ FRAMING
☐ INSULATION
☐ FINAL
☐ AS BUILT - SURVEY
☐ DEMO - SITE

- ☐ DEMO - FINAL
☐ PLUMBING RI
☐ PLUMBING FINAL
☐ MECHANICAL RI
☐ MECHANICAL FINAL
☐ WOOD BURNER/FIREPLACE
☐ WATER HOOK-UP
☐ SEWER HOOK-UP
☐ SEPTIC INSTALL

- ☐ SEPTIC FINAL
☐ EXCAV/GRADING/FILLING
☐ TREE REMOVAL
☐ SITE INSPECTION
☐ RATED WALLS
☐ COMPLAINT
☐ FOLLOW-UP
☐ FOUNDATION/REMOVAL

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS:

4" HDPE bored from 6" at street
to SE corner of home.

5lb hip test for 15 minutes. All OK

CODE REQUIREMENTS ARE FOR YOUR INFORMATION

- ☒ WORK SATISFACTORY: PROCEED
☐ CORRECT WORK & PROCEED
☐ CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING
☐ CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN
☐ STOP ORDER POSTED. CALL INSPECTOR
☐ INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.

- ☒ PROJECT COMPLETE
☐ ISSUE CERTIFICATE OF OCCUPANCY
_____ TEMPORARY
_____ PERMANENT
☒ PHOTO TAKEN
☐ CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: B. J.

Inspector: Scott