

**CITY OF ORONO  
INSPECTION NOTICE**

**PERMIT NO.** SNP22-000087

**CALLED IN**  
**SCHEDULED**  
**COMPLETED**

**DATE**

**TIME**

10/31  
11/1/22  
\_\_\_\_\_

10:00 AM  
\_\_\_\_\_

**ADDRESS** 2205 Bayview

**OWNER** \_\_\_\_\_

**TELEPHONE NO.** \_\_\_\_\_

**CONTRACTOR** Reid 763 245 4087

**DESCRIPTION**

Sewer Inspection (Water Done 10/28)

- |  |  |  |
|--|--|--|
| <input type="checkbox"/> FOOTING               | <input type="checkbox"/> DEMO - FINAL          | <input type="checkbox"/> SEPTIC FINAL          |
| <input type="checkbox"/> POURED WALL           | <input type="checkbox"/> PLUMBING RI           | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL        | <input type="checkbox"/> TREE REMOVAL          |
| <input type="checkbox"/> LATHE                 | <input type="checkbox"/> MECHANICAL RI         | <input type="checkbox"/> SITE INSPECTION       |
| <input type="checkbox"/> FRAMING               | <input type="checkbox"/> MECHANICAL FINAL      | <input type="checkbox"/> RATED WALLS           |
| <input type="checkbox"/> INSULATION            | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT             |
| <input type="checkbox"/> FINAL                 | <input type="checkbox"/> WATER HOOK-UP         | <input type="checkbox"/> FOLLOW-UP             |
| <input type="checkbox"/> AS BUILT - SURVEY     | <input type="checkbox"/> SEWER HOOK-UP         | <input type="checkbox"/> FOUNDATION/REMOVAL    |
| <input type="checkbox"/> DEMO - SITE           | <input type="checkbox"/> SEPTIC INSTALL        |  |

**OWNER/CONTRACTOR TO MEET YOU:** YES NO

**COMMENTS:** 4" Sch 40 PVC Sewer Service

75' long with tracer wire + Angle

5/8" Air test for 15 minutes

all OK

Has to live 6" to manhole

☒ **WORK SATISFACTORY: PROCEED**

☒ **PROJECT COMPLETE**

☐ **CORRECT WORK & PROCEED**

☐ **ISSUE CERTIFICATE OF OCCUPANCY**

☐ **CORRECT WORK, CALL FOR REINSPECTION  
BEFORE COVERING**

\_\_\_\_\_ **TEMPORARY**

☐ **CORRECT UNSAFE CONDITION WITHIN \_\_\_\_\_ HOURS.  
INSPECTOR WILL RETURN**

☒ **PHOTO TAKEN**

☐ **STOP ORDER POSTED. CALL INSPECTOR**

☐ **CITATION ISSUED**

☐ **INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.**

**Call for the next inspection 24 hours in advance. (952) 249-4600**

**Owner/Contractor on site:** Reid

**Inspector:** Scott