

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

**CITY OF ORONO
INSPECTION NOTICE**

PERMIT NO. SWP22-000095

CALLED IN

SCHEDULED

COMPLETED

DATE

TIME

12/22

12/28/22

9:00 AM

ADDRESS 2265 Webber Hills Road

OWNER

TELEPHONE NO.

CONTRACTOR Steinbrecher Companies

DESCRIPTION Sewer Repair

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: 1 1/4 copper to p/astic on
E-1 tank was the repair.

Where p/astic discharge line connects to
E-1 pump tank had a crack & spraying
sewage.

☒ **WORK SATISFACTORY: PROCEED**

☐ **CORRECT WORK & PROCEED**

☐ **CORRECT WORK, CALL FOR REINSPECTION
BEFORE COVERING**

☐ **CORRECT UNSAFE CONDITION WITHIN _____ HOURS.
INSPECTOR WILL RETURN**

☐ **STOP ORDER POSTED. CALL INSPECTOR**

☐ **INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.**

☒ **PROJECT COMPLETE**

☐ **ISSUE CERTIFICATE OF OCCUPANCY**

_____ **TEMPORARY**

_____ **PERMANENT**

☒ **PHOTO TAKEN** -Videos

☐ **CITATION ISSUED**

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site:

Inspector: