

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

CITY OF ORONO
INSPECTION NOTICE
PERMIT NO. SWP22-000041

11/11
CALLED IN 8/8/22 DATE
SCHEDULED 8/12/22 TIME
COMPLETED 8-15 3:00

ADDRESS 2670 Pheasant Road

OWNER _____ TELEPHONE NO. _____

CONTRACTOR Leadons Excavating Ted 612-490-4993

DESCRIPTION Sewer Connection (Water done 8/16/22)

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: _____

68' From house to Cleanout
4" Schedule 40 TO Cast iron
Approx 4 1/2' Deep
going to cover pipe with Styrofoam
in Driveway Area.

5 PSI 15 min.
Lined From 68' From house to main

- | | |
|---|---|
| <input type="checkbox"/> WORK SATISFACTORY: PROCEED | <input checked="" type="checkbox"/> PROJECT COMPLETE |
| <input type="checkbox"/> CORRECT WORK & PROCEED | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING | _____ TEMPORARY |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN | _____ PERMANENT |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR | <input type="checkbox"/> PHOTO TAKEN |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS. | <input type="checkbox"/> CITATION ISSUED |

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: Leadon excavating

Inspector: Clint Schumann

TASK # 66951