

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!

CITY OF ORONO
INSPECTION NOTICE
PERMIT NO. SWP25-000028

CALLED IN
SCHEDULED
COMPLETED

DATE

TIME

6/2/25

11 am

ADDRESS 1545 Minnie Avenue

OWNER _____ TELEPHONE NO. 602-919-4345

CONTRACTOR DSM Excavating

DESCRIPTION Sewer Connection Inspection

- | | | |
|--|--|--|
| <input type="checkbox"/> FOOTING | <input type="checkbox"/> DEMO - FINAL | <input type="checkbox"/> SEPTIC FINAL |
| <input type="checkbox"/> POURED WALL | <input type="checkbox"/> PLUMBING RI | <input type="checkbox"/> EXCAV/GRADING/FILLING |
| <input type="checkbox"/> FOUNDATION DRAIN TILE | <input type="checkbox"/> PLUMBING FINAL | <input type="checkbox"/> TREE REMOVAL |
| <input type="checkbox"/> LATHE | <input type="checkbox"/> MECHANICAL RI | <input type="checkbox"/> SITE INSPECTION |
| <input type="checkbox"/> FRAMING | <input type="checkbox"/> MECHANICAL FINAL | <input type="checkbox"/> RATED WALLS |
| <input type="checkbox"/> INSULATION | <input type="checkbox"/> WOOD BURNER/FIREPLACE | <input type="checkbox"/> COMPLAINT |
| <input type="checkbox"/> FINAL | <input type="checkbox"/> WATER HOOK-UP | <input type="checkbox"/> FOLLOW-UP |
| <input type="checkbox"/> AS BUILT - SURVEY | <input type="checkbox"/> SEWER HOOK-UP | <input type="checkbox"/> FOUNDATION/REMOVAL |
| <input type="checkbox"/> DEMO - SITE | <input type="checkbox"/> SEPTIC INSTALL | |

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS: _____

THIS IS THE FIRST PART.

THE SECOND HALF WILL NEEDED
TO BE TELIVGED AND POSSIBLE
LINER RUN. ALL 4" SCH 40 PVC.
5.5 PSI FOR 15 MIN + NO LOSS

SGE ATTCH: Task # - 95464

- | | |
|---|---|
| <input type="checkbox"/> WORK SATISFACTORY: PROCEED | <input type="checkbox"/> PROJECT COMPLETE |
| <input type="checkbox"/> CORRECT WORK & PROCEED | <input type="checkbox"/> ISSUE CERTIFICATE OF OCCUPANCY |
| <input type="checkbox"/> CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING | _____ TEMPORARY |
| <input type="checkbox"/> CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN | _____ PERMANENT |
| <input type="checkbox"/> STOP ORDER POSTED. CALL INSPECTOR | <input type="checkbox"/> PHOTO TAKEN |
| <input type="checkbox"/> INSPECTION REQUIRED. CALL TO ARRANGE ACCESS. | <input type="checkbox"/> CITATION ISSUED |

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: _____

Inspector: Jason Flor

CITY OF ORONO
INSPECTION NOTICE
PERMIT NO. SWP25-000028

CALLED IN
SCHEDULED
COMPLETED

DATE

TIME

6/2/25

11am

ADDRESS 1545 Minnie Avenue

OWNER _____

TELEPHONE NO. 602-919-4345

CONTRACTOR DSM Excavating

DESCRIPTION

Sewer Connection Inspection

- ☐ FOOTING
- ☐ POURED WALL
- ☐ FOUNDATION DRAIN TILE
- ☐ LATHE
- ☐ FRAMING
- ☐ INSULATION
- ☐ FINAL
- ☐ AS BUILT - SURVEY
- ☐ DEMO - SITE

- ☐ DEMO - FINAL
- ☐ PLUMBING RI
- ☐ PLUMBING FINAL
- ☐ MECHANICAL RI
- ☐ MECHANICAL FINAL
- ☐ WOOD BURNER/FIREPLACE
- ☐ WATER HOOK-UP
- ☐ SEWER HOOK-UP
- ☐ SEPTIC INSTALL

- ☐ SEPTIC FINAL
- ☐ EXCAV/GRADING/FILLING
- ☐ TREE REMOVAL
- ☐ SITE INSPECTION
- ☐ RATED WALLS
- ☐ COMPLAINT
- ☐ FOLLOW-UP
- ☐ FOUNDATION/REMOVAL

OWNER/CONTRACTOR TO MEET YOU: YES NO

COMMENTS:

THIS IS THE FIRST PART.

THE SECOND HALF WILL NEEDED
TO BE TELIVGED AND POSSIBLE
LINER RUN. ALL 4" SCH 40 PVC.
5.5 PSI FOR 15 MIN + NO LOSS

SGE ATTCH: Task # 95464

- ☐ WORK SATISFACTORY: PROCEED
- ☐ CORRECT WORK & PROCEED
- ☐ CORRECT WORK, CALL FOR REINSPECTION BEFORE COVERING
- ☐ CORRECT UNSAFE CONDITION WITHIN _____ HOURS. INSPECTOR WILL RETURN
- ☐ STOP ORDER POSTED. CALL INSPECTOR
- ☐ INSPECTION REQUIRED. CALL TO ARRANGE ACCESS.

- ☐ PROJECT COMPLETE
- ☐ ISSUE CERTIFICATE OF OCCUPANCY
_____ TEMPORARY
_____ PERMANENT
- ☐ PHOTO TAKEN
- ☐ CITATION ISSUED

Call for the next inspection 24 hours in advance. (952) 249-4600

Owner/Contractor on site: _____

Inspector: _____

White Copy/Inspector's File

Canary Copy/Site Notice

CODE REQUIREMENTS ARE FOR YOUR PERSONAL HEALTH AND SAFETY!